

October 8, 2025

Request for Proposals for Geotechnical and Tsunami Hazard Testing and Report Services for the Del Norte Healthcare Revitalization Project

RFI Responses/Addendum 1

1. Will pavement design recommendations be needed for the project?

Response: The Civil Engineer on the design team will be responsible for the pavement design recommendation (ie. pavement thickness, subgrade treatment and section design), but requires the Geotech to provide sub surface investigation, soil properties, and Geotech recommendations as these are critical input for the Civil Engineer's design.

Eureka

7351 Tompkins Hill Rd
Eureka, CA 95501
(707) 476-4100

Del Norte

883 W. Washington Blvd
Crescent City, CA 95531
(707) 465-2380

Eureka Downtown

525 D Street
Eureka, CA 95501
(707) 476-4500

Klamath-Trinity

65 Orchard St.
Hoopa, CA 95546
(530) 625-4821